

MANUFACTURER'S DECLARATION OF CONFORMITY

No.	EX.048-2020
Issuer's name:	GEWISS S.p.A.
Issuer's address:	Via A. Volta, 1 24069 Cenate Sotto (BG) ITALY
Object of the declaration:	<p>MDC 60 ratings and installation conditions</p> <p>Number of poles = 3P – 4P</p> <p>Rated current = 6 A – 32 A</p>

We declare that the products mentioned above have been tested according to the following Standards:

Standard	Title	Edition/Date of issue
EN 61009-1	Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs) Part 1: General rules	2012 + A1:2014 + A2:2014 + A11:2015 + A12:2016
EN 61009-2-1	Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs) for household and similar uses (RCBOs) Part 2-1: Applicability of the general rules to RCBO's functionally independent of line voltage	1994 + A11:1998

We also declare that they are suitable to be used in electrical installation with the following ratings:

- *Rated Voltage* *Un=230 V*
- *Maximum prospective short circuit current in the installation point* *Icc= 10 kA*

Signed for and on
behalf of:

GEWISS S.p.A.

Place and Date: **Cenate Sotto, 20 May 2020**

MATTEO GAVAZZENI
Corporate Industrial Property,
Standards, Quality Marks and
Certifications Manager